



MF Program Action Item

Action Item Number: 2011-114 Date Submitted: 04/28/11 Submitted By: MALS-16

Problem/Project Description:

The NA 19-600-141-6-1 "APPLICATION" section states "Preoperational Checklist maintenance requirements shall be accomplished after initial installation and prior to each use." "Prior to each use" is unclear verbiage that is often interpreted as 'daily' by inspecting officials, even as ECUs installed in active MFs remain in the 'ON' position continuously to maintain a climate controlled environment for the sensitive test equipment each work center may have inside. Because of the vagueness, many commands require MF users and Work Center 990 to maintain a /52 pre-op card on each ECU, a time wasting effort that adds no value to the Mobile Facility Program.

Recommendation:

Recommend deletion of the NA 19-600-141-6-1 in its entirety.
Recommend modifying the NA 19-600-141-6-2, CARD iii "INDEX". Add "Initial installation into an MF" under Inspection Type and "1-5" under "Card Numbers". Performing all cards and documenting the work via maintenance action form will cover all aspects of the NA 19-600-141-6-1 if it is deleted as requested.

Status/Course of Action: (Funded Yes No N/A)

06/22/11 - MFPO - Recommend change Pre-Op card to read: "Preoperational Checklist maintenance requirements shall be accomplished after initial installation and any time after MF has been completely shut down or source power has been removed and re-established.
Change will be effective for R-22 & R-134 MRC.

Action Agency: NAWCADLKE Assigned To: Jamie Green Date Assigned: 06/15/11

Est. Completion Date: 12/31/11 Act. Completion Date: _____ Closed By: _____