

MOBILE FACILITY PROGRAM REVIEW
ACTION ITEM

ACTION ITEM NO.: 6-44

DATE SUBMITTED: 04/21/08

SUBMITTED BY: MALS-11 SSgt Clark, W/C 990 577-1944

PROBLEM: The MEP-807 and MEP-809 Tactical Quiet Generators (TQGs) are being received brand new from the manufacturer. The technical publication requires the TQGs to be started and operated upon acceptance and every 30 days following. The requirement for utilization of the generators in garrison, other than preventive maintenance and acceptance inspections, is not needed.

RECOMMENDATION: Recommend preservation for all TQGs not being utilized in garrison upon completion of acceptance inspection.

STATUS: 04/22/08 CLOSED--This is an ASL/MARFO/WING issue not an MF program issue. MF program does not determine use and storage of fleet equipment until disposition is requested.

05/29/08 CLOSED--Fleet has been briefed.

ACTION AGENCY: MF Program Office