

MOBILE FACILITY PROGRAM REVIEW
ACTION ITEM

ACTION ITEM NO.: 6-50

DATE SUBMITTED: 04/21/08

SUBMITTED BY: MALS-11 SSgt Clark, W/C 990 577-1944

PROBLEM: The MEP-807 and MEP-809 Tactical Quiet Generators (TQG's) are being received brand new from the manufacturer. The MALS is required to unwrap them and perform an acceptance inspection. The TQG's are left exposed to the environment and are vulnerable to internal and external corrosion. Corrosion treatment would be a waste of man hours if it could possibly be prevented.

RECOMMENDATION: Recommend funding for an environmentally controlled facility to prevent degradation of possibly preserved generators.

STATUS: 4/22/08 - CLOSED The MF program does not fund preservation of items nor buildings or leases. This is a MARFOR/WING issue.

ACTION AGENCY: MF Program Office