

ACTION ITEM NO: 1-103

DATE SUBMITTED: 15 JUN 00

SUBMITTED BY: CG SECOND MAW

PROBLEM:

Mobile Expandable Rigid Wall Shelter (MERWS) Input/Output Power.

DISCUSSION:

Current configuration of MERWS allows for (2) two 100 AMP Power Inputs. If a Power Distribution Box (PDB) is used, all 100 AMP Outputs are used for this shelter alone.

RECOMMENDATION:

Change MERWS Power Panel to a 200 AMP Input and a 100 AMP Output.

ACTION AGENCY:

NADEPNI (Code 48701)

STATUS: 15 JUN 00

Open. Engineering Change Request Form completed and forwarded to COMMARFORLANT for concurrence on 14 Jun 2000, copy also forwarded to 3<sup>rd</sup> MAW ALD-E.

COMPLETION DATE:

15 DEC 00