

ACTION ITEM NO: 2-155

DATE SUBMITTED: 18 JUN 99

SUBMITTED BY: CG SECOND MAW

PROBLEM:

200KW Generators (HY-04/05).

DISCUSSION:

The 10% reductions of assets in Aug 96 decreased all MALS by (2) two, 200KW Generators. The Input Power alone for the HY-04/05 Test Station is 1200 Amps or (2) two 200KW Generators. Also, the new Vari-Drive Test Station for 620 is coming soon and its' power requirement is as large, if not larger. As of now, if required to deploy, we would not have enough Generator support.

RECOMMENDATION:

Give back the Generators. Plus, look at the requirement for the Vari-Drive.

STATUS: 07 JUL 99

ACTION AGENCY:

CMC ASL-34

COMPLETION DATE:

TBD

STATUS: 15 JUN 00

ACTION AGENCY:

1. CG FIRST MAW
2. CG FOURTH MAW

Open. During Logistics Review Group (LRG) Meeting held at New Orleans, La. on 15 June 2000,

CMC ASL-34 requested 1<sup>st</sup> MAW and 4<sup>th</sup> MAW submit their respective present Generator-Repair Status according to Table of Basic Allowance (TBA) through appropriate Chain-of-Command.

COMPLETION DATE:

15 JAN 01