



MF Program Action Item

Action Item Number: 2011-116 Date Submitted: 04/28/11 Submitted By: MALS-16

Problem/Project Description:

As of 1 August 2010, NA 19-600-152-6-2 has a new requirement for a 30-day PM on MFs to test the emergency ballasts, standalone lights, and GFI circuit breaker. This creates an additional workload of several hundred PMs per month. Additionally, there are now four PMs in every 91 day period (30, 30, 30 & 91) as the 30 and 91 day PMs will not sync up.

Recommendation:

Recommend this requirement be moved to the 91-day PM portion of the NA 19-600-152-6-2.

Status/Course of Action: (Funded Yes No N/A)

06/22/11 - MRCs to be updated; 30 second requirement cycle will become the 30, 60, 90 day PM with 182 becoming 180 and 364 a 360.

Action Agency: NAWCADLKE Assigned To: Jamie Green Date Assigned: 05/03/11

Est. Completion Date: 12/31/11 Act. Completion Date: _____ Closed By: _____