

MOBILE FACILITY PROGRAM REVIEW
ACTION ITEM

ACTION ITEM NO.: 3-86

DATE SUBMITTED: 04/20/07

SUBMITTED BY: SSGT McClure, W/C 64D, MALS-11

PROBLEM: CASS ECUs go down and cause the bench to overheat making them inoperable.

RECOMMENDATION: Upgrade ECUs to be able to support the high usage.

STATUS: 05/18/07 Closed. New ECUs are currently being fielded to provide better reliability and the incorporation of digital thermostats will allow the ECUs to run mor efficiently.

ACTION AGENCY: Mobile Facilities Program Office