

MOBILE FACILITY PROGRAM REVIEW
ACTION ITEM

ACTION ITEM NO.: 5-42

DATE SUBMITTED: 04/11/07

SUBMITTED BY: Sgt Dustin Elliott, W/C 990, MALS-39

PROBLEM: All publications for MEP-105A and MEP-009A Generator sets are outdated. These are Army publications, with the most recent update dated 28 June, 1995. Many of the part numbers in these publications are either obsolete, incorrect, or take upwards of 6 months to receive.

RECOMMENDATION: Expedite replacement of MEP-009A and MEP-105A Generator sets with new MEP-809A and MEP-807A Tactically Quiet Generator sets. The Army has already upgraded their generator fleet to the new TQG sets, and no longer updates the publications for the MEP-009A and MEP-105A Generator sets.

STATUS: 05/18/07 Closed. TQG delivery schedule active. Delivery of TQG to army contract. MFP has no control of delivery schedule.

ACTION AGENCY: Mobile Facilities Program Office