

ACTION ITEM NO: 6-28

DATE SUBMITTED: 19 AUG 98

SUBMITTED BY: MALS-31

PROBLEM:

Power receptacles for the MEP-009A and MEP-105A Generators.

DISCUSSION:

Currently, the Fleet utilizes Plug-to-Lug (pigtail) power cable requirements to facilitate power connectors. This method is both wasteful, impractical and unsafe.

RECOMMENDATION:

It is requested that 100 Amp and 200 Amp receptacles be added to the MEP-009A and MEP-105A generators. This method would allow the utilization of standard Mobile Facility (MF) power cables within the present inventory to meet the power connection requirements.

STATUS: 29 JUL 98

ACTION AGENCY:

NAWCADLKE (Code 4825)

Open. NAWCADLKE Code 4825 to provide analysis.

COMPLETION DATE:

16 NOV 98

STATUS: 14 SEP 98

NEW ACTION AGENCY:

NAWCADLKE (Code 1.1.X.7.1.6.B)

Open. NAWCADLKE Code 1.1.X.7.1.6.B to provide analysis.

COMPLETION DATE:

16 NOV 98.

STATUS: 02 DEC 98

Closed. Authority to approve and investigate this change resides with DOD Program Manager Mobile Electric Power (P-MEP).