

**MOBILE FACILITY PROGRAM REVIEW
ACTION ITEM**

ACTION ITEM NO.: 6-34

DATE SUBMITTED: 04/23/07

SUBMITTED BY: Sgt Neal, MALS-41

PROBLEM: Naval Message 212113Z FEB 07 denies authorization for calibration of the Robin-Air Recovery and Recycling unit. The ST-1000 is of no use to the Mobile Facilities program IAW LRG's 6-24, 6-31 and 6-32. Those LRG's state the ST-1000 is an ineffective unit and is not certified by the ARI or UL which is a requirement of the EPA

RECOMMENDATION: Authorize the use of the Robin-Air Model No. 17800A Recovery unit for the Mobile Facility Program. This unit is designed to recover R-12, and R-22 which are utilized in the environmental control units. This recovery unit is also certified by both (ARI) and (UL), which is a requirement by the EPA.

STATUS: 05/18/07 In review for applicable approach.
05/19/07 (Response from IMRL-MGyStg Olmos) Both assets listed on the Chit are IMRL assets and inventory is held in the fleet. Current IMRL inventory must be accomplished on a per unit bases. Attached is the SERD data for each NIIN which will list each POC for the asset. This Action Item is Closed.

ACTION AGENCY: Mobile Facilities Program Office/IMRL