

MOBILE FACILITY PROGRAM REVIEW
ACTION ITEM

ACTION ITEM NO.: 6-36

DATE SUBMITTED: 04/11/07

SUBMITTED BY: Sgt Dustin Elliott, W/C 990, MALS-39

PROBLEM: No funding is currently available for generators in need of depot level maintenance. 46% of MALS-39 MEP-009A Generator sets are in a rework (Depot level repair) status.

RECOMMENDATION: Expedite replacement of MEP-009A and MEP-105A Generator sets with new MEP-809A and MEP-807A Tactically Quiet Generator sets. Even if funding were to become available to send rework generator sets to Depot level maintenance, application of that funding would be more useful if applied to acquire new TQG sets.

STATUS: 05/18/07 Closed. Repeat of 5-42.

ACTION AGENCY: Mobile Facilities Program Office