

MOBILE FACILITY PROGRAM REVIEW
ACTION ITEM

ACTION ITEM NO: 6-41

DATE SUBMITTED: 04/18/07

SUBMITTED BY: AS1(AW) Ken White, Expeditionary Logistics Unit ONE

PROBLEM: MEP-009A Generators need replacement or rework. ELU-1 has seven assets all of which are extremely worn.

RECOMMENDATION: Replace MEP-009 Generator with compatible Tactical Quiet Generator (TQG) or rework assets using GWOT rework funding.

STATUS: 5/23/07 Closed. This issue will be rectified with the TQGs that are inbound for the Marine and Navy fleet. Granted the Navy is not due for TQG implementation until FY09. In the interim, as the Marine Corps off loads legacy generators this summer/fall we will supplement the Navy with these RFU assets until the off-load in FY09. Also, supplemental funding has been requested for Navy legacy generators.

ACTION AGENCY: MF Program Office