

MOBILE FACILITY PROGRAM REVIEW  
ACTION ITEM

ACTION ITEM NO.: 6-54

DATE SUBMITTED: 04/09/09

SUBMITTED BY: MALS-13

**PROBLEM:** The MF Checklist enclosure 1 to MCO13670.1 page 11 asks if Ancillary Equipment in storage is stored out of the elements and protective covers (if applicable) installed. Most sites do not have enough shelter available to house the TQG's and MMG's in order to keep them protected from the weather.

**RECOMMENDATION:** Recommend environmental protection for all TQG's and MMG's similar to Cocoon Inc manufactured covers.

**STATUS:** 05/21/09 - TQG preservation facility is planned for construction in Albany. If local shelter is required, recommend MILCON. AI CLOSED.

ACTION AGENCY: MF Program Office