

ACTION ITEM NO: 7-39

DATE SUBMITTED: 19 JUL 98

SUBMITTED BY: MALS-31

PROBLEM:

Environmental Control Unit (ECU)-108 availability.

DISCUSSION:

The ECU-108 is an internal 400 Hz converter located within the Mobile Facility (MF). MALS-31 currently has five MF's with this type of unit installed. The Fleet has tried to procure the items from the supply system and the items are not available. Upon further review, there were over 60 items located at PWC Norfolk to be sent to DRMO or sold to other services. These items, although reliable, need to be maintained and made available to the Fleet activities.

RECOMMENDATION:

Stock ECU-108 in the supply system for procurement by the Fleet in case of installed equipment failure.

STATUS: 29 JUL 98

ACTION AGENCY:

NAWCADLKE (Code 4825)

Open. NAWCADLKE Code 4825 to provide analysis.

COMPLETION DATE:

16 NOV 98

STATUS: 14 SEP 98

NEW ACTION AGENCY:

NAWCADLKE (Code 3.1.4.4)

Open. NAWCADLKE Code 3.1.4.4 to provide analysis.

COMPLETION DATE:

16 NOV 98

STATUS: 02 DEC 98

Open. There are 20 units still in PWC Norfolk. NAVICP cannot take over management because ECU-108 is 2V Cog., NAVAIR managed. NAVAIR PMA-260 must change the Cog Code from 2V to 3M.

COMPLETION DATE:

15 JUN 99

STATUS: 15 JUL 99

Open. No current status to date.

COMPLETION DATE:

TBD

STATUS: 13 JAN 00

Closed. The ECU-108 Inventory (20 units) will remain NAVAIR managed (2V Cog) and to be kept in stock at PWC Norfolk, Virginia issued on an "as required" basis to fill individual Fleet requisitions, until present stock is exhausted.