

ACTION ITEM NO: 8-06

DATE SUBMITTED: 19 JUL 98

SUBMITTED BY: MALS-31

PROBLEM:

Fleet Site-Survey.

DISCUSSION:

With the advent of the "new" HCT-10 (HY-04/05) Mobile Facility (MF), a serious power concern faces the Fleet and the availability of utility power. This situation is further magnified should this MF be forward deployed. The input power requirements require 1200 Amps. No "station" utility currently exist to meet this requirement, without major restructuring.

RECOMMENDATION:

Conduct adequate Site-Surveys of respective MALS to ensure the necessary power requirements can and will be met before MF's are procured and shipped to the Fleet.

STATUS: 29 JUL 98

ACTION AGENCY:

PMA-260

Open. COMNAVAIR Code 3.1B.4 to hand-carry to PMA-260 for action.

COMPLETION DATE:

01 OCT 98

STATUS: 28 APR 99

Open. No current status to date.

STATUS: 15 JUL 99

Open. No current status to date.

COMPLETION DATE:

TBD

STATUS: 15 JUN 00

Closed. During Logistics Review Group (LRG) Meeting held at New Orleans, La. on 15 June 2000, COMNAVAIRSYSCOM Code 3.9.4 closed Action Item No. 8-06 and requested re-submit utility-power requirements through appropriate TYCOMS Chain-of-Command.